THE STATE OF THE S

The West Bengal Power Development Corporation Limited

(A Government of West Bengal Enterprise)
Corporate Identity No.:U40104WB1985SGC039154

BANDEL THERMAL POWER STATION

Tribeni, Hooghly-712503 **Office of The General Manager** Ph. No.: 033-2684 6369, Fax No.-033-2684 6151

Corrigendum

Tender Reference No: WBPDCL/BTPS/NIT/E1449/18-19

Tender ID

: 2018_WBPDC_199424_1

Name of Work

: PQR Corrigendum for Procurement of LED light for different area continuous

illumination (24X7 HRS.), BTPS, WBPDCL.

Clause Reference: Section I (Notice Inviting Tender) Under Sl. No 18 (SPECIAL INSTRUCTIONS TO THE BIDDER). Following modifications or additions in above mentioned clause or other section in NIT document will be applicable.

- Well glass LED fitting (Item Sl. No. 1.04 & 1.06 of price part of NIT document) cover will be polycarbonate diffuser with IK08 protection.
- 2. All LED fixtures must have
 - a) LM-79 report from NABL accredited laboratory.
 - b) LM-80 report from Chip manufacturer along with TM 21 report confirming service life.
- 3. For all LED fixtures Watt should be less than or equal to the mentioned maximum Watt in description satisfying all other required specification.
- 4. For LED tube light (Item Sl. No. 1.05 & 1.14 of price part of NIT document) Lumen Output will be minimum 2200 lumen.
- 5. For all LED fixtures photobiological test report against UV protection, ROHS report & REACH report to be submitted.
- The warranty clause will be revised as "The standard free replacement guarantee/ warrantee for complete
 fitting including Driver will be at least 36 months or more (for indoor/outdoor LED Luminaries) from the
 date of supply.
- 7. BIS certification with all respect (fittings & Drivers) will be applicable to all the NIT mentioned items.

All other criteria will be remained same.

DGM (M&C)

Bandel Thermal Power Station, WBPDCL