



The West Bengal Power Development Corporation Limited

(A Government of West Bengal Enterprise)

Corporate Identity No.:U40104WB1985SGC039154

BANDEL THERMAL POWER STATION

Tribeni, Hooghly-712503

Office of The General Manager

Ph. No.: 033-2684 6369, Fax No.-033- 2684 6151

Corrigendum

Tender Reference No: WBPDC/BTPS/NIT/E1544/19-20

Tender ID : 2019_WBPDC_224649_1

Name of Work : Specification Corrigendum for Supply & Delivery of Energy Efficient LED Luminaries for CHP, BTPS, WBPDC.

Clause Reference : Section IV of Notice Inviting Tender , (SCOPE OF SUPPLY & TECHNICAL SPECIFICATION). Following modifications or additions in above mentioned section in NIT document will be applicable.

- i. Total system lumen efficacy will be $\geq 10,000$ lumen efficacy for Item No. 1 & 2.
- ii. System lumen efficacy ≥ 100 lumen / watt or higher in place of energy efficiency of SL. No. 1(vi), SL. No. 2(vii) & SL. No. 3(v).
- iii. Technical Specification SL. No. 3(ii) will be mounting through bracket instead of pole mounted.
- iv. Total lumen efficacy for Item No. 3 will be ≥ 3500 .
- v. System lumen efficacy from Item No. 3 will be ≥ 100 lumen / watt or better in place of energy efficiency.
- vi. Wattage range of Item No. 4 will be (18 – 20) W in place of (35 – 40) W.
- vii. Total system lumen efficacy will be ≥ 1800 or higher of Item No. 4.
- viii. Driven out efficiency $\geq 85\%$ instead of $> 90\%$.
- ix. Power factor of Item No. 4 will be 0.90 instead of 0.95.
- x. Party have to submit declaration, indicating LM No. Itemwise in TDS or company's letter head.

All other criteria will remain same.

DGM (M&C)

Bandel Thermal Power Station, WBPDC

Registered & Corporate Office:

'Bidyut Unnyan Bhavan', Plot – 3/C, LA – Block, Salt Lake City, Sector – III, Kolkata – 700 098

Phone : 033-2335-0445/2335-0571/2339-3100 Fax : 033-2339-3286/2335-0516 website : www.wbpdcl.co.in.