

## **CORRIGENDUM FOR TECHNICAL BIDS**

**NIT NO: WBPDC/STPS/NIT/E2246/20-21**

**TENDER ID: 2020\_WBPDC\_307867\_1**

**“Supply, Erection, Testing & Commissioning of 130 MVA, 220kV/132kV/33kV Tie-Transformer under EM(OPH) Dept., Santaldih T.P.S., the WBPDC”**

### **Amendment of clauses for E-Tender :**

- 1) As per NIT clause No: 8.16.1 (NIT Page No: 79) and clause No: 20 of Annexure-X (NIT Page No: 107) of technical specification, **the neutral CT** is not to be mounted in common turret. However the separate tank may be mounted on turret.
- 2) As per NIT clause No: 9(ii) of Annexure-X (NIT Page No: 105) of technical specification, **Grounding transformer** is in the WBPDC's scope.
- 3) As per NIT clause No: 13 of Annexure-X (NIT Page No: 105) of technical specification, **insulation level** is to be as per the technical specification of the NIT.
- 4) As per NIT clause No: 26 of Annexure-X (NIT Page No: 107) and clause No: 8.8.2 (NIT Page No: 74) of technical specification, **termination LV**: LV terminal is to be brought out through top cover mounted bushing. Terminal arrangement of the bushing must be suitable for connection of 33KV armoured conductor.
- 5) Other **Terms & Conditions** including all Technical Specification remain same as per the NIT.

### **M&C Dept.**

Santaldih Thermal Power Station

P.O. : Santaldih Thermal Plant

Dist. : Purulia (W.B.)

PIN - 723 146