

THE WEST BENGAL POWER DEVELOPMENT CORPORATION LIMITED
(A Govt. of West Bengal Enterprise)
Bakreswar Thermal Power Project
P.O.Bk.T.P.P , Dist -Birbhum,Pin -731104

NIT No.: WBPDCCL/Tend-Adv/CC/14-15/208/BkTPP Date:14.02.2015

SUB: Tender document for Procurement of Rail Poles for 33KV Overhead Transmission Lines at Bakreswar Thermal Power Project.

SALE OF TENDER PAPER : **23/02/2015 to 13/03/2015 from 10:00 Hrs. to 14:00 Hrs.** on all working days except Sundays and holidays and Saturday from 10:00 Hrs. to 12:00 Hrs. against deposition of Cost of Tender Document at Cash Section of Bk.TPP.

PRE-BID DISCUSSION ON : **On 18/03/2015 at 11:00 Hrs.**

LAST DATE & TIME OF SUBMISSION OF TENDER PAPER : **10/04/2015 upto 14:30 Hrs.**

DATE & TIME OF OPENING (PART-A FOR TECHNICAL BID ALONGWITH COMMERCIAL TERMS & CONDITIONS) : **10/04/2015 at 15:00 Hrs.**

COST OF TENDER PAPER : **Rs. 500/- (Rupees five hundred only)**

DEPOSITED VIDE D.C.R.NO. _____

DATED _____

ISSUED TO M/s. _____

SR. MANAGER (Materials)
BAKRESWAR THERMAL POWER PROJECT
W. B. P. D. C. L.

THE WEST BENGAL POWER DEVELOPMENT CORPORATION LIMITED
(A Govt. of West Bengal Enterprise)
Bakreswar Thermal Power Project
P.O.Bk.T.P.P , Dist -Birbhum, Pin -731104

NIT No.: WBPDC/Adv-Tend-CC/14-15/208/BKTPP Date:14.02.2015

Sealed tender in two parts, Part A (for technical specification bid alongwith commercial Terms & Conditions) and Part B (for price bid) in duplicate are invited by the General Manager, Bakreswar Thermal Power Project (BkTPP) under The West Bengal Power Development Corporation Limited from interested, resourceful and experienced agencies.

The agencies should submit the following documents in their quotation while submitting the offer:

1. Valid I.T. & S.T., Service Tax Registration, Professional Tax Clearance Certificates, Provident Fund A/c. No. etc.
2. Credential of similar work done directly under a Government/Quasi Government Organization/Private Company during period of any three year within last seven years reckoning **from 31.12.2014**
 - “Similar Works” means ‘Supply of Rail Pole for 33KV Overhead Transmission Line’ with the specifications detailed elsewhere in the Tender Document.
 - The value of work for similar type of job as mentioned above, completed by agency should be as follows:
 - a) In single order of value not less than Rs. 12 lakhs.
or
 - b) In two orders each of value not less than Rs. 07 lakhs.
or
 - c) In three orders each of value not less than Rs. 06 lakhs.
3. Average Annual Financial Turnover in last 3 financial years, (viz. 2011-12, 2012-13 & 2013-14) should be at least Rs. 04 lakhs.
4. Average net worth in last three financial years:- should be positive.
5. Audited balance sheet for last three financial years.

Job Description:

Procurement of Rail Poles for 33KV Overhead Transmission Lines as per detailed technical specification at Bakreswar Thermal Power Project.

Completion time

Material Delivery Schedule: - Twenty (20) weeks from the date of the order. Delivery is to be effected at BkTPP Store. Unloading will be done by WBPDC.

Earnest Money Deposit

Rs. 30,000/- (Rupees thirty thousand only) in the form of Demand Draft or Bank Guarantee in favour of “THE WEST BENGAL POWER DEVELOPMENT CORPORATION LIMITED” drawn on /issued by any Nationalised /Scheduled

Bank, Suri or United Bank of India, BkTPP Branch. The requisite earnest money should be deposited along with tender papers in a separate sealed envelope. No tender will be entertained without Earnest Money. NSIC holders are exempted from deposition of EMD. Necessary enlistment certificate should be submitted by the respective bidder.

Cost of Tender Paper

Rs. 500/- (Rupees five hundred) in cash only (non refundable)

Sale of Tender Paper

23/02/2015 to 13/03/2015 from 10:00 Hrs. to 14:00 Hrs. on all working days except Sundays and holidays and Saturday from 10:00 Hrs. to 12:00 Hrs. against deposition of Cost of Tender Document at Cash Section of BkTPP.

Pre-bid Discussion

On 18/03/2015 at 11:00 Hrs. at the Administrative Building of BkTPP. Bidders are requested to submit their queries before the Pre-bid discussion.

Last Date of Submission of Tender Papers:

Last date of submission of Tender Paper is 10/04/2015 upto 14:30 Hrs. and the same will be opened (Part-A) at 15:00 Hrs. on the same date in presence of the participating tenderers if any. Sealed tenders of the parties only who have deposited the requisite amount of Earnest Money will be opened for two part bid.

The Corporation reserves the right to accept / cancel any or all tenders or to split the work without assigning any reason whatsoever. The WBPDCCL does not bind itself to accept the lowest tender and qualification of tenderer will be adjudged as per sole discretion of WBPDCCL authority. The validity of tender will remain effective for 6 (six) months from the date of opening of Price Bid of tender. All other details are available in the tender document.

Enclo:

- Information to Bidders
- Annexure – I & II

(K. Sarkar)
Sr. Manager (Materials)
BkTPP/WBPDCCL

THE WEST BENGAL POWER DEVELOPMENT CORPORATION LIMITED
(A Govt. of West Bengal Enterprise)
Bakreswar Thermal Power Project.
P.O. Bk.T.P.P, Dist-Bibhum. Pin-731 104

NIT No.: WBPDC/Adv-Tend-CC/14-15/208/BkTPP Date:14.02.2015

INFORMATION TO BIDDERS

Sub :	Tender document for Procurement of Rail Poles for 33KV Overhead Transmission Lines as per detailed technical specifications at Bakreswar Thermal Power Project.
-------	---

1.00.00. INTENT OF SPECIFICATION

This proposal is for procurement of 35 (Thirty Five) nos. New Rail Poles for BkTPP 33KV Overhead transmission Lines.

This specification is intended to cover the following activities in respect procurement of above mentioned material to be supplied to Central Store, BkTPP, WBPDC located in Birbhum district of West Bengal.

- a. Detailed design of the item.
- b. Providing Detail drawing & Quality Assurance (QA) Plan for buyer's approval and records.
- c. Packing and transportation of material from the manufacturer's works to the site, including road clearance, if required.
- d. Unloading, handling, storage and insurance of equipment.

2.00.00. GENERAL INSTRUCTION TO BIDDER

1. The bidder is advised to visit the plant/site, if required, and collect any information or data as may be required by them, before quoting against this specification. The bidder is also advised to give technical information of the material which is being quoted along with relevant literature covering all technical specifications and its features.
2. Bidder to check receipt of complete documents referred to in the contents. In the event of order, the entire specification will form part of purchase order for compliance during execution.
3. Deviation, if any, shall be clearly brought out in the "Deviation Schedule". Otherwise, it will be interpreted that the bidder is fully complying with the specification.
4. In case of any dispute, Senior Manager (EM-OPH)'s decision will be final and binding.

3.00.00 BID PROPOSAL

1. Following documents shall be submitted along with the offer. The documents forming part of the offer shall be neat, legible and in English.

1.1. Detail drawing along with descriptions.

1.2. Filled in "Deviation Schedule" with reason/justification for the deviation taken.

1.3. List and schedule of documents to be submitted by bidder for buyer's approval and information, after placement of order.

4.00.00 SCOPE OF WORK (SOW):

1. It includes design & engineering, testing and supply of Rail Poles at site. Detail drawing is to be get finalized (mutually agreed by supplier & customer) according to site requirement. Vendor may visit site for collection of required data/ drawing etc. before finalization of engineering of the item without any financial implication to WBPDCCL.
2. Quantity of the item is to be finalized after designing of material.
3. **Testing:** Before dispatching of equipments and materials vendor should offer for customer testing at their works. All basic designing have to be completed before offering customer inspection
4. Packing and transportation from the manufacturer's works to the site including road clearance, as required.
5. If the bidder feels that, in his opinion, certain feature brought out in his offer are superior to what has been specified, these may be highlighted separately.
6. Warranty period of Rail Poles has to be of Minimum 18 months after delivery or 12 months after successful installation, which is earlier starting from the date of acceptance of WBPDCCL.

5.00.00 BID QUALIFYING REQUIREMENT:

1. Bidders must have the experience of manufacturing Rail Poles for 33KV Overhead transmission Line system for at least past 03 years in India.
2. Bidder should have supplied orders of similar type to at least three to other government or reputed organizations.
3. Transport & Insurance will be in the scope of the vendor and details of the same are to be submitted in the offer.

6.00.00 TERMS AND CONDITIONS

Sealed Tender in two parts, Part A (for Technical Specification bid alongwith commercial terms and conditions) and Part B (for Price Bid) in duplicate (Non-transferable) with firm's own seal are invited as detailed in the attached sheet ANNEXURE-II under following terms and conditions:-

1. WBPDCCL reserves the right to split up any or all tender(s) if necessary without assigning any reason(s) to the participating vendors what so ever.
 2. Tender Notice No. Brief description of the supply and due date of opening should be clearly mentioned on the top of the envelope.
 3. Material Delivery Schedule: - Twenty (20) weeks from the date of the order. Delivery is to be effected at Bk.TPP Store. Unloading will be done by WBPDCCL.
 4. LEAF LET ETC: - The descriptive literature of materials shall have to be enclosed along with the tender / quotation.
 5. INSPECTION:-
 - a) The complete equipment has to be offered for inspection by WBPDCCL representative at bidder's works and the bidder shall give 30 days advance notice for arranging the inspection after the equipment is made fully ready. Inspection will be carried out by our representative at your works, if required. Inspection will also be carried out at BkTPP stores by the representatives of concerned dept after effecting delivery.
 - b) Decision of Sr. Manager (EM-OPH), BkTPP would be final & binding for inspection at vendor's works & vendor must offer for inspection by WBPDCCL at their site.
 - c) The Rail Poles can be dispatched only after the clearance by WBPDCCL.
 6. PRICE:-
 - a) Rates and total amount should be mentioned both in figure and words, if there be any difference the fewer amounts will be considered.
 - b) Excise duty, S.T. /VAT, Service Tax, other statutory Levies, Forwarding & Packing & freight etc must be clearly mentioned in the tender/quotation.
 - c) The rates inclusive of delivery at Bk.T.P.P. Stores must be quoted. Break up should also be submitted.
 - d) The D G S & D rate should be quoted, if there be any D G S & D rate contract that is to be furnished.
 - e) Bids or modification of bids received after opening of Tender will not be considered.
 7. **PAYMENT:**
 - i) 90% payment will be made by Cheque against Store Received Voucher (SRV). The SRV will be issued only after acceptance of material by user department. Payment by Demand Draft with bank charges on vendor's account may be considered subject to mention in relevant quotation / offer.
 - ii) Balance 10% of payment will be released after 12 months from the date of successful installation of equipment or 18 months after delivery of the materials, whichever is earlier.
- PAYING AUTHORITY:**
- Bill in triplicate alongwith challans is to be submitted to the G.M (F&A)/ Dy.GM (F & A), WBPDCCL Corporate Office. STD Form for concessional rate of S.T can be provided to the supplier only after completion of supply with submission of final bill. Excise duty can not be without E. Duty Gate Pass (GP-I) E.D. Gate Pass is to be submitted in original along with the Invoice/Bill. Part payment for part delivery will not be allowed.
8. TEST CERTIFICATE:- Material test certificate from Govt. Approved Laboratory may be submitted along with supplies.

9. GUARANTEE/WARRANTY:- Vendor has to give guarantee against manufacturing defects of the item for 12 months after successful installation or 18 months after delivery, whichever is earlier. Any problems/defects found in any part of the materials are to be rectified by the vendor or replacement to be done at free of cost. In case of failing to do so; a penalty may be imposed seeing the seriousness of problem. Decision of Sr. Manager (EM-OPH), Bk.TPP regarding the delay & penalty etc. would be final & binding. Guarantee Certificate for supplied material is to be submitted along with material.
10. PERFORMANCE BANK GUARANTEE:- A Bank Guarantee for 5% of the limiting value of basic price will be submitted for security cum performance guarantee. The said Bank Guarantee will be furnished prior to commencement of supply of materials and Bank Guarantee will remain valid till expiry of the guarantee period.
11. LIQUIDATED DAMAGE:- The WBPDCCL reserves the right to repudiate the contract if the materials are not delivered within the stipulated time. However, the authority may waive this condition and impose a L.D. for delayed supply @1/2% on the value of undelivered materials which may be either for total quantity or delivery effected partly beyond the scheduled time and for each week of delay or part thereof up to a maximum of 5% of the total value of the materials.
12. OTHER REQUIREMENTS:- Copies of orders received from Govt. agencies, Undertaking along with proof of execution of the orders shall have to be furnished along with the bids.

Notwithstanding any thing stated above WBPDCCL reserves the right to assess the bidder's capability and capacity to perform the contract, should be circumstances warrant such assessment in the overall interest of WBPDCCL.

WBPDCCL reserves the right to split the order, alter the quantity and reject any or all tenders without assigning any reasons whatsoever. WBPDCCL does not take any responsibility for postal delays.

SR. MANAGER (Materials)
BAKRESWAR THERMAL POWER PROJECT
W. B. P. D. C. L.

ANNEXURE-I

TECHNICAL SPECIFICATION

FOR

35 Nos. RAIL POLES for 33KV Overhead Transmission Line at Bakreswar Thermal Power Project:

Sl No.	Item Code	Item Description	Quantity	UOM
1	04T070103	Rail Pole, Height (approx) - 12.81 Mtrs, Weight - 51.69 Kg/Mtr Or 104.6 Pound/Yard.	455	MTR.

1. GENERAL TECHNICAL SPECIFICATIONS

Technical particulars of New Rail Poles for 33KV Overhead Transmission Line.

- Height of Each Pole - 12.81 mtrs. To 13.0 mtrs.
- Sectional Weight of Poles - 50Kg per Mtr.(Min) to 60Kg per Mtr.(Max) preferably 51.69Kg per Mtr. Or 104.6 Pound per Yard.
- Total number of pieces- Should not be less than 35 nos.
- Total Length – 455 Mtrs.

N.B.

1. ***Rail Poles to be procured in pieces, each piece of height ranging in between 11.0 mtrs and 13.5 mtrs preferably 12.81 mtrs each.***
2. ***Total no of pieces should be not less than 50 nos.***
3. ***Sectional weight of each Rail Pole should be of minimum 50kg/mtr and maximum of 60kg/mtr.***

